

**Ambient Monitoring Summary**

Monitored Parameter	Monitoring Station				SCAQMD Rule 1420.1 Limit
	#1	#2	#4	#5	
Lead ( $\mu\text{g}/\text{m}^3$ , 30-Day Average)	0.044	0.054	0.040	0.041	0.100 $\mu\text{g}/\text{m}^3$ , 30-Day Average.
Arsenic ( $\text{ng}/\text{m}^3$ , 30-Day Average)	1.316	1.209	1.007	1.096	10 $\text{ng}/\text{m}^3$ , 24-Hour Average.

**Wet Electrostatic Precipitator (WESP) Monitoring Summary**

Monitored Parameter	Monitoring Location	SCAQMD Title V Permit Limit
	WESP Outlet, Xact 640 Result	
Arsenic (lbs/year Annualized Average)	0.830	6.500 Pounds Per Year, Permit Condition E448.6(A.)

**Stack Test Results Summary: Busch Units**

Most Recent Test	Stack Emission Source	Lead (lbs/hour)	Arsenic (lbs/hour)
July, 2025	Busch Unit A	0.00001570	0.00000230
July, 2025	Busch Unit B	0.00001500	0.00000145
July, 2025	Busch Unit C	0.00001390	0.00000301
July, 2025	Busch Unit D	0.00001370	0.00000081
June, 2025	Busch Unit E	0.00024700	0.00000475
June, 2025	Busch Unit F	0.00025300	0.00000813
June, 2025	Busch Unit G	0.00048300	0.00001440
January, 2025	Busch Unit H	0.00002489	0.00000991
January, 2025	Busch Unit I	0.00007266	0.00000547
January, 2025	Busch Unit J	0.00020083	0.00005338
January, 2025	Busch Unit K	0.00013432	0.00000237

**Stack Test Results Summary: Wet Electrostatic Precipitator (WESP)**

Most Recent Test	Stack Emission Source	Lead (lbs/hour)	Arsenic (lbs/hour)	Benzene (lbs/hour)	1,3-Butadiene (lbs/hour)
February, 2025	Wet Electrostatic Precipitator (WESP)	0.00121610	0.00005350	---	---
December, 2023	Wet Electrostatic Precipitator (WESP)	---	---	0.02420000	0.00223000

Busch Unit + WESP Totals	0.00269011	0.00015947	0.02420000	0.00223000
Rule 1420.1 Limit	0.00300000	0.00114000	0.05140000	0.00342000